

# VOC Content Test Certificate

Tuesday, September 20<sup>th</sup>, 2013

Manufacturer: Durotech Industries (14 Essex Street, Minto NSW 2566)

Sample Description: Duro Mastic BLW

Date Tested: August 2013 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

<b>Specification</b>	
<b>Green Building Council of Australia Green Star Office Design V3 IEQ-13</b>	<b>Duro Mastic BLW</b>
Architectural Sealant 250 grams per Litre as VOC content per material	<b>8 grams per Litre as VOC content per material</b>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Nick Joy  
BSc(Hons)  
Consultant

CV130817a