

# VOC Content Test Certificate

Tuesday, 19<sup>th</sup> December 2017

Supplier: Durotech Industries (14 Essex Street, Minto, NSW, 2566).

Sample Description: Durotech Water Proofing Adhesive - Duroseal 25LM.

Date Tested: November 2017 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

<p><b>Specification</b></p> <p><b>Green Building Council of Australia</b></p> <p><b>Green Star Design &amp; As Built V1.1 13.1.1</b></p> <p><b>Green Star Interiors V1.1 12.1.1B</b></p>	<p><b>Duroseal 25LM</b></p>
<p>Water Proofing Membranes and Sealant: 250 grams per Litre as VOC content per material</p>	<p><b>65 gram per Litre as VOC content per material</b></p>
<p><i>We hereby certify Duroseal 25LM Product is well below the VOC content limits of chosen category set by Green Building Council of Australia.</i></p>	



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Tuan Duong  
BE (Chem. Eng.)  
Consultant



Nick Joy  
BSc (Hons)  
Consultant

CV171109A